


Three-Sided Sections Are To Be Manufactured To ASTM C-1504 Specifications As Required.

In Traffic Areas w/Less Than 2' of Cover, Non-Shrink Grout Must Be Placed In The Top Deck Keyway Only. Joints To Be Sealed w/EZ-Wrap or Equal and Covered w/22" Wide Filter Fabric.

Inlets And Outlets To Penetrate Through End Caps To Maintain Structural Integrity Of The Bridge Sections.

Span, Rise And Length Of Retention Chamber To Be Determined By Required Capacity.

For Spans Greater Than 24'-0"

	401 Kelton St Bay City, MI 48706		Typical Precast Concrete Hy-Span Retention System				
	5281 Lansing Rd Charlotte, MI 48813	2701 Chicago Dr SW Wyoming, MI 49519					
	4950 White Lake Rd Clarkston, MI 48346	3756 Centennial Rd Sylvania, OH 43560	Date 16 May 16	Revised	Rev. No.	Drawn By BmG	Scale NTS